

**TOWN OF HAMPSTEAD  
PROVINCE OF QUEBEC**

**DRAFT BY-LAW NO. 1031-1**

---

**BY-LAW MODIFYING BY-LAW 1031  
ON THE USE AND SUPPLY OF  
POTABLE WATER AND  
ADMINISTRATION OF USED WATER  
(SEWAGE SERVICES).**

---

**WHEREAS** notice of motion of Draft By-law no. 1031-1 was given at the Special Council Meeting held on August 30th, 2021.

**WHEREAS** Draft By-law no. 1031-1 was adopted at the Special Council Meeting held on August 30<sup>th</sup>, 2021.

**WHEREAS** all Council members received a copy of the present By-law and declare having read it;

**ON \*\*\*\* \* 2021, THE COUNCIL DECREES AS FOLLOWS:**

**1. Article 9.1.5 is modified to be read as follow:**

It is the responsibility of the proprietor to ensure that the water meter is installed in a location easily accessible for maintenance and repair. The water meter must be installed within four feet (4'-0'') of where the water main pipe enters the building ~~and placed just after the main water supply shut off valve.~~ There must be an unobstructed access facing the meter of minimally 18" x 18" with an empty space between it and the wall of minimally 2". For meters imbedded in walls or floors, a trap door must be installed allowing for immediate access.

**2. Article 9.1.10 is modified to be read as follow:**

Both the water meter and the water main supply shut off valve meter must at all times be equipped with a seal installed by a Town Officer. Only a Town Officer may break a seal.

**3. This present By-law will come into force according to law.**

---

Dr. William Steinberg, Mayor

---

M<sup>c</sup> Pierre Tapp OMA, Town Clerk